



JEFFERSON COUNTY DRAINAGE DISTRICT NO. 6  
*Karen K. Johnson, MBA, CTCD, CTCM: Chief Business Officer*

---

6550 Walden Rd., Beaumont, Texas 77707 Phone: 409-842-1818 Fax: 409-842-2729

IFB Number: IFB 26-009/KKJ  
IFB Title: Corley Diversion Project  
IFB Originally Due by: 2:00 PM, CST, July 9, 2026  
IFB Due by Addendum No. 2: 2:00 PM, CST, July 23, 2026  
Addendum No.: 3  
Issued (Date): June 25, 2026

**TO BIDDER:** This Addendum is an integral part of the IFB package under consideration by you as a Bidder in connection with the subject matter herein identified. Drainage District No. 6 deems all sealed bids to have been proffered in recognition and consideration of the entire IFB package – including all addenda. For purposes of clarification, receipt of this present Addendum by a Bidder should be evidenced by returning it (signed) as part of the Bidder's sealed bid. If the Bid has already been received by the Jefferson County Drainage District No 6 Purchasing Department, Bidder should return this addendum in a separate sealed envelope, clearly marked with the IFB Name, IFB Number, and Opening Date and Time, as stated above.

---

**Reason for Issuance of this addendum: Clarification.**

- 1. Question:** Should there be a Prep ROW Bid Item? There is a lot of clearing, tree limb trimming, misc. demolition, and other work not shown on the plans that would typically be covered under Prep ROW:  
**Answer:** Bid item 78 provides for Shrub Removal and item 79 provides for Tree Removal, and all other misc. demolition shall be incidental to the other bid items.
- 2. Question:** The cross sections show using 6" of flex base under the box culverts. With groundwater conditions being what they are, the flex base will become "mushy", due to the fines in the material. The flex base really needs to be changed to #57 graded limestone, which has very little fines.  
**Answer:** #57 Crushed Stone may be used as bedding under the proposed box culverts and junction boxes.
- 3. Question:** Can a bid item be added for dewatering of the box culvert installation?  
**Answer:** Dewatering shall be incidental to the box culvert installation.
- 4. Question:** Can you clarify scope required for the Surface Restoration Bid Items? For instance, on Segment how did you calculate 113,000 SY of surface restoration? Are all areas disturbed to be sodded?  
**Answer:** All areas disturbed outside of the paved area within the right-of-way shall be sodded.

---

All addendums will be posted on the DD6 website:  
<https://dd6.org/departments/purchasing/notices-for-bid/>

The information included herein is hereby incorporated into the documents of this present Bid matter and supersedes any conflicting documents or portion thereof previously issued.

---

Receipt of this Addendum is hereby acknowledged by the undersigned Bidder:

ATTEST:

\_\_\_\_\_  
Witness

\_\_\_\_\_  
Authorized Signature (Bidder)

\_\_\_\_\_  
Witness

\_\_\_\_\_  
Title of Person Signing Above

\_\_\_\_\_  
Typed Name of Business or Individual

Approved by \_\_\_\_\_ Date